



NOTE: FOR POLE UNIT DIMENSIONS, REFER TO DRAWING NO. 0-1022.

VENTILATION: WHEN THE SWITCHES ARE TOTALLY ENCLOSED, VENTILATING LOUVERS MUST BE PROVIDED YIELDING A MINIMUM OF 7" SQUARE INCHES NEAR THE TOP OF THE ENCLOSURE, AND 7" SQUARE INCHES NEAR THE BOTTOM OF THE ENCLOSURE.

AMPS	H
500	NONE
1200	NONE
1600	50
2000	50
2500	50
3000	120

(SDC-SY-SDC) SERIES VL SWITCHES WITH GREYVA DIAL OPERATOR		
NO.	DESCRIPTION	DATE BY / BY

FRONT VIEW
RECOMMENDED ENCLOSURE DESIGN

Q-1137