



NOTE: FOR POLE UNIT DIMENSIONS, REFER TO DRAWING NO. 0-1022.

VENTILATION: WHEN THE SWITCHES ARE TOTALLY ENCLOSED, VENTILATING LOUVERS MUST BE PROVIDED YIELDING A MINIMUM OF 7" SQUARE INCHES NEAR THE TOP OF THE ENCLOSURE, AND 7" SQUARE INCHES NEAR THE BOTTOM OF THE ENCLOSURE.

AMPS	H
500	NONE
1200	NONE
1600	50
2000	50
2500	50
3000	120

0-11-37 (SIC-BY-200) SERIES VL SWITCHES WITH GREVA DIAL OPERATOR		
NO.	REVISED	DATE BY

REV 2 0-10-84 JAE OMC PROGRAM 2-P CHANGED FROM OMITTING RIGHT POLE TO OMITTING CENTER POLE

See 2-10-84 at P. 2 of O. - ORIGINAL WORK SHEET, 0-11-37